

Liège, 11th May 2016.

Range Approval Report

n° 1043/2016

NORME BELGE

NBN C 30-004 3^{ème} Ed. 2004	Fils nus, conducteurs et câbles - Généralités Comportement au feu des câbles électriques - Classification et méthodes d'essais pour la classification	Add. 1 (2005) Add. 2 (2008)
--	--	--------------------------------------

1. Test applied for by: Mr A. Pristerà for Berica Cavi s.p.a., Via della Meccanica 2, I-36040 Meledo di Sarego (VI), Italy.
2. Approved range of cables (*: information given by the sponsor):
*Reference: SOLAR CABLE 0.6/1 kV PV1-F TÜV 2 Pfg1169/08.2007.
Cable marking : BERICA CAVI S.P.A. ITALY PV CABLE FG21M21 IEMMEQU & TUV
TYPE APPROVED PV1-F ROHS CE Year/Lot Type.

Range of approved sections:

Type	Product Code (*)
1x2,5	B8801250
1x4	B8801400
1x6	B8801600
1x10	B88011000
1x16	B88011600
1x25	B88012500
1x35	B88013500
1x50	B88015000
1x70	B88017000
1x95	B88019500
1x120	B880112000
1x150	B880115000
1x185	B880118500
1x240	B880124000

3. Reference documents : Test reports ISSeP nr 1041 & 1042 /2016.
4. Classification:

Taking the test results reported in the documents quoted in § 3 into account, the range of cables described in §2 belong to category F2 according to NBN C 30-004.



Wallonie


S. DESMET,
Test Executive.

Remark : This report can only be reproduced in full, except with the laboratory's agreement.

Report n° 1043/2016, page 1/1