

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHIECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1180213

Product: Control and signalling cable, Al/PET tape screen, fire retardant, halogen free and fire resistant

Type: EUROSAFE JE-H(St)H EF E30/E60

Rating: (1 - 24) x 2 x (0,6 - 0,9) mm; 300 V, B_{2ca}-s1,d0

Ordering firm: BERICA CAVI S.P.A.
Via della meccanica, 12, 36040 Meledo di Sarego VI, Italy

Manufacturer: BERICA CAVI S.P.A.
Via della meccanica, 12, 36040 Meledo di Sarego VI, Italy

Factories: BERICA CAVI S.P.A.
Via della meccanica, 12, 36040 Meledo di Sarego VI, Italy

Trade mark:

The test results are stated in the test-report No.: 800312-01/02 of: 21.03.2018

A sample of the product was found to be in conformity with:

ČSN EN 61034-1:06+A1:14, ČSN EN 61034-2:06+A1:14, ČSN EN 60332-2-1:05,
ČSN EN 60332-1-1:05+A1:16, ČSN EN 60332-1-2:05+A1:16+A11:17,
ČSN EN 50200 ed.3:16, ČSN EN 1363-1:02, DIN VDE 4102-12:98, DIN VDE 4102-2:77,
STN 92 0205:10, ZP 27/2008, ČSN EN 50399:12+A1:17

Other data:

The validity of the certificate is limited to: 31.03.2021

28.03.2018

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



Stamp



800312-01